

**Central County Emergency 911  
22 Weis Avenue  
Ellisville, MO 63011**

**Air-Cooled Split Computer Room Air Conditioning System**

**General Conditions**

- Model:** Provide equipment pricing and model of equipment and factory specs as outlined in drawings.
- Removal:** Provide pricing for removal of old equipment and plan to keep one unit fully operational during the process, while considering that the 911 center needs to stay fully functional during this process.
- Install:** Provide pricing for installation of new equipment and plan to keep one unit operational during the process, while considering that the 911 center needs to stay fully functional during this process.
- Critical:** **The 911 center is an essential facility therefore; operations cannot be interrupted and must be able to stay fully functional during process.**
- Back up:** Provide back-up contingency plan to keep AC in room should it be needed in an emergency.
- Hours:** Access will be given to perform work from 7:00 am and 5:00 p.m. weekdays.
- Optional:** Separate out any optional or additional charges.
- Coordination:** Timeline for removal and install must be presented. Coordination meetings must be held to ensure project stays on schedule and alarm center stays fully functional.
- Testing/Training:** Testing and Training should be completed prior to systems being turned over to 911 center.
- Warranty:** Provide warranty and also extended warranty options as an additional line item in bid proposal if available past the factory warranty.
- Certificate of Insurance:** Must provide a Certificate of Insurance

**Submit sealed bid by March 16, 2020 at 12:00 p.m. CST**